



OPERATING INSTRUCTION

Reliable Measurement of Gas

Read the instructions before starting work!



Manufacturer Contact our customer service department for technical information:

Address	RMG Messtechnik GmbH Otto-Hahn-Str. 5 D-35510 Butzbach
Main office	+49 6033 897 - 0
Service	+49 6033 897 - 0
Spare Parts	+49 6033 897 - 173
Fax	+49 6033 897 - 130
E-Mail	service@rmg.com

Original Document The RMGView^{USM} operation instruction for the USM GT400 from June, 26th 2018 is a translation of the original German manual. Anyhow, this document may serve as reference for translations into other languages.

Remark Please use in case of any uncertainties the German version as main reference.

Note Unfortunately, paper is not updated automatically, whereas technical development continuously advances. Therefore, we reserve the right to make technical changes in regard to the representations and specifications of these operating instructions. The latest version of this manual (and the one of other devices) can be downloaded at your convenience from our Internet page:

www.rmg.com

Creation date	2014, January 16 th
1st revision	2015, May 29 th
2nd revision	2017, September 29 th
3rd revision	2018, June 26 th

Document version and language

Document version	RMGView ^{USM} – 2018 / 06 / 26
Language	EN

1 Introduction

- 1.1 Motivation for the software2
- 1.2 About this manual3

2 Installation

- 2.1 System requirements8
- 2.2 Files delivered8
- 2.3 Preparing devices for connection.....9
- 2.4 Installing software10
- 2.5 Configuring the site and devices12
- 2.6 Ensuring connection20
- 2.7 Adding further devices to the site.....21

3 Software overview

- 3.1 Operating and display elements.....24
- 3.2 Standard buttons.....28
- 3.3 Status icons29
- 3.4 User levels31
- 3.5 Structure of the software32
- 3.6 Data/readings/parameters.....38
- 3.7 Help function39
- 3.8 File types.....40
- 3.9 Password41
- 3.10 License.....41

4 Software description

- 4.1 Site overview.....46
- 4.2 Dashboard48
- 4.3 Values52
- 4.4 Lists.....54
- 4.5 Plots56
- 4.6 Raw data57
- 4.7 Logs59
- 4.8 Errors64
- 4.9 Password Input65
- 4.10 Record data66
- 4.11 Edit list (Creating a new list).....67
- 4.12 New User-Defined List:
Select Type68

- 4.13 Site Specific,
User-Defined List (plot)69
- 4.14 Color, Line Thickness71
- 4.15 Save Plot as jpg Image72
- 4.16 Information on installation73
- 4.17 USM settings74
- 4.18 Log Player.....77
- 4.19 Inspection Test78
- 4.20 Password List88
- 4.21 User Settings89
- 4.22 Base line correction)91
- 4.23 License Info93
- 4.24 Process License93
- 4.25 Report Editor.....93

5 Operation

- 5.1 User settings96
- 5.2 Adjusting the size of
graphic contents99
- 5.3 Working with windows.....100
- 5.4 Parametrize USE105
- 5.5 Open Folder User Data.....109
- 5.6 Open Appdata Folder110
- 5.7 Screen dump in jpg format.....111
- 5.8 Reading error and
warning messages112
- 5.9 Creating a log of user actions113
- 5.10 Creating a log on
parameter changes115

6 Troubleshooting

- 6.1 Cfg file missing118
- 6.2 Discontinuity in connection
to the meter.....119
- 6.3 Display „RMGView^{USM} is
already running....“120
- 6.4 Display „The file
USE_112c.rmx ...“120

7 Index

8 Glossary



1 Introduction

In this chapter you will receive general information on the manual and on the device.

Contents

1.1	Motivation for the software	2
1.2	About this manual	3
1.2.1	Trademarks	3
1.2.2	Objective of the manual	4
1.2.3	Prerequisite knowledge required	4
1.2.4	Structure of information screens	4
1.2.5	Abbreviations used	5
1.2.6	Symbols used	5
1.2.7	Validity	6

1.1 Motivation for the software




Fig. 1-1: Application example

You can manage several sites with the RMGView^{USM} software. For every site you can include as many devices with their connection data as you wish. Using these Modbus addresses, data can be read from the device and data can be transmitted from the PC (A) to the device.

The example shows how three sites (B, C, D) can be managed with the RMGView^{USM} software. For every site, Modbus addresses are set up using RMGView^{USM} to enable a connection to the devices.

- For site 1 (B), two Modbus addresses (E) were set up to establish the connection.
- For site 2 (C), one Modbus address (F) was set up.
- For site 3 (D), two Modbus addresses (G) were set up.

With RMGView^{USM} you can:

- set up and manage several sites.
- assign several devices (USM) to a site and manage them.
- read out the actual measured values (actual values) in real time.
- display values in table form, as diagrams, as graphics or in individual fields.
- request predefined lists that read out and show certain parameters from the device.
- request predefined plots that display the parameters in a diagram.
- create user defined lists and output them as reports.
- create user defined plots that display the parameters in a diagram.
- RMGView^{USM} automatically recognizes the firmware of the attached device. Only those parameters that are functional with the attached device are displayed.
- parameterize the attached device.
- create test reports.

1.2 About this manual

In this chapter you will receive information regarding the organization and objective of the manual and the knowledge prerequisites needed by the reader.

1.2.1 Trademarks

All the hardware and software names used in the manual may also be registered trademarks of third parties or under other brand protection. In this respect, the trade mark rights of third parties are to be respected.

1.2.2 Objective of the manual

The manual provides you with the information that is needed for trouble-free and safe operation.

The software is state of the art and conceived and programmed according to the recognized safety standards and guidelines.

However, hazardous situations may arise as a result of their use.

Possible hazards for:

- functions of the connected devices

For this reason, you may only operate the software as intended and in technically defect-free condition.

1.2.3 Prerequisite knowledge required

The manual assumes that the users are familiar with Microsoft Windows operating system and the operating elements, e.g. drop-down menus, buttons etc. MS Windows typical screens e.g. **Save As...** and their operating elements are not described in this manual.

1.2.4 Structure of information screens

The following information screens are used in the manual.

Notice

This warning screen informs you of potentially hazardous situations that can occur as a result of incorrect operation or human error. If these situations are not avoided, they can result in material damage to the machine or in the vicinity.



This information gives you tips on how to simplify your work. With this screen, you additionally receive further information on the product or the work process.

1.2.5 Abbreviations used

In this chapter of the manual, the abbreviations used are explained.

AGC	Automatic Gain Control
ca.	circa, approximately
as app.	as applicable
max.	maximum
MC	Measurement Canada
MID	Measurement Instruments Directive
min.	minimum
SNR	Signal-to-Noise Ratio
SoS	Speed of Sound (ultrasonic velocity)
TD	Transducer
TNG	Transducer of a certain type.
USE	Ultrasonic electronics
USM	Ultrasonic gas meter
e.g.	For example

1.2.6 Symbols used

The following symbols are used:

1, 2, ...	Steps within a work operation.
	Marks steps in an illustration that are described in the text.
(A)	Reference to a component (element) marked with a letter in an illustration.
	Marks elements in an illustration. The arrow points to the element being described.
	Cross reference to another part in this manual or in another document.
Print Screen	Switches, regulators, slides, buttons and other terms from the software are marked by bold text.

1.2.7 Validity

This manual describes the software RMGView^{USM}.

The softwareRMGView^{USM} is only a part of a complete site system. Please also observe the manuals of the other components of the site in order to guarantee safe operation.

2 Installation

In this chapter you will be given information on the system requirements for the PC, on the software installation and on making a connection to the device.

Contents

2.1	System requirements	8
2.2	Files delivered	8
2.3	Preparing devices for connection	9
2.4	Installing software	10
2.5	Configuring the site and devices	12
2.5.1	Set up-language and start window	16
2.5.2	Enter user data	19
2.6	Ensuring connection	21
2.7	Adding further devices to the site	22

2.1 System requirements

The PC must fulfill following specification:

- Operating system Microsoft Windows 7 (32 Bit and 64 Bit) and Windows 10 (64 Bit)
- Min. screen resolution of 1024 × 768 pixel
- A converter that converts the signal for RS 232 / RS 485 is required for USB or COM interfaces.

2.2 Files delivered



Fig. 2-1: Files delivered

You will receive various files on delivery of the RMGView^{USM} software. As an example the installation files and the associated rmx files in RMGView^{USM} 5.0 version are shown.

2.3 Preparing devices for connection

During installation, information on the COM port or the IP address will be required in order to make a connection between the software and the ultrasonic electronics.




Fig. 2-2: Connection scheme

The following connection options to the USE are available to you:

- Connection via a serial COM port (RS 485/RS 232) on the PC.
PC (A) and USE (B) are connected with a cable.
- Connection via IP address.
For this the PC is connected to the Internet.

■ Determine connection data

- 1 Determine the IP address of the USE respectively the name of the COM port on the PC.

2.4 Installing software



In order to install the new version of RMGView^{USM} it is not necessary to uninstall the older version.

■ Starting installation

- 1 Double click here on the installation file e.g. RMGView^{USM}installer xxx.exe.

The window RMGView^{USM} **X.X Setup** opens.



Fig. 2-3: Agree to license contract

You must read the license contract and agree to it in order to continue with the installation.

- 2 Check the box **I agree to the terms and conditions of the license contract.**

3 Click the **Install** button.

The status of the installation is illustrated by an animated time bar.

The successful installation is displayed in the RMGView^{USM} **xxx Setup** window.



Fig. 2-4: Finish installation

4 Click the **Finish** button.

The installation is then completed.

■ Connect PC

1 Connect the PC with the IP address of the device via the network.

Or

Connect the USE cable to the COM port on the PC.

⇒ COM port: see the USE operating instructions



Connection via cable

Use the following cable:

- Twisted pair and shielded cable
- maximum length 500 m
- Type LiYCX 2 × 2 × 0.75 mm²

2.5 Configuring the site and devices

■ RMGView^{USM} start

- 1 Press the **Windows** key on the keyboard.
- 2 Click menu entry **RMGViewUSM**.

A start screen will be displayed.



Fig. 2-5: Start screen

After the starting sequence the **Select Site** screen will be displayed.



Fig. 2-6: Select Site screen

With RMGView^{USM} you can manage several sites.
You can install and monitor several devices at every site.

■ Assigning site names

After starting the RMGView^{USM} software, a site is shown in the **Select Site** window with the title **New Site 1**.

You can give this site a random name.

- 1 Click on **New Site 1** with the right mouse button.
The context menu is opened.
- 2 Click on the menu entry **Rename** and assign a name.
- 3 Confirm the name with the **Enter** key.

The **Select Site** window closes. The **USM Settings:** window **Modbus** opens.



Using the context menu you can start following actions:

- Menu entry **New Folder**: File sites in folders.
- Menu entry **New Site**: Create further sites.
- Menu entry **Delete Site**: Delete sites. The devices in the site are also deleted.

In this window you can create a first device and set up the connection.




Fig. 2-7: USM settings window: Modbus

You have two alternatives for creating a connection to the device.

Connection via:

- IP address
- COM port on the PC

■ Setting up devices (Ultrasonic gas meter)




Fig. 2-8: USM settings window: Modbus

- 1 Select the device to which you want to create a connection.
- 2 Rename the device - if you require.
- 3 Enter the Modbus address with which the device should operate.
- 4 Define type of connection
 - ☒ IP Address
⇒ continue at step 5
 - ☐ COM Interface
⇒ continue at step 6

For connections via IP Address 5 enter the IP Address of the USE.
⇒ continue at step 9

Via COM port 6 Select value **38400** for the baud rate.
7 Select value **8N1** for Bits, Parity, Stop Bits.
8 Select COM port on the PC to which the USE is connected.

Finish set up 9 Click button **Apply**.

The **USM settings window** closes. The **Site Overview - RMGView^{USM}** window opens. Location and meter for the device are defined in this window.



If you want to create further connection data for a device, you will find information for this under:

⇒ „Adding further devices to the site“ on page 21

2.5.1 Set up-language and start window

■ Activate the window for user options

1 Activate **Dashboard - All USMs** window.

⇒ Chapter 4.1, „Site overview“ on page 46




Fig. 2-9: Menu entry select user settings

2 Click on menu **Settings** in the menu ribbon.

3 Click on menu entry **User Settings**.

The **User Settings: User Interface** menu bar opens.

■ Set language




Fig. 2-10: Set language

- 1 Open drop down menu **Language** and select the appropriate entry.
- 2 Click **OK** button.

The settings are saved.

■ Set-up start screen

You can define a window as start screen that is displayed after the software is started. The windows that can be cued via the multifunction bar can be selected.

⇒ Chapter 3.1, „Operating and display elements“ on page 24




Fig. 2-11: Set-up start screen

- 1 Open drop down menu **Start with..** and select appropriate entry.
- 2 Click **OK** button.
The settings are saved.

2.5.2 Enter user data

■ Open window for site information

- 1 Activate **Dashboard - All USMs** window.
⇒ Chapter 4.1, „Site overview“ on page 46




Fig. 2-12: Select menu entry Site Information

- 2 Click on menu **Settings** in the menu bar.
- 3 Click menu entry **Site Information**.
The **Site information** window opens.

■ Enter values




Fig. 2-13: Select menu entry Site Information

- 1 Complete fields **Name**, **Client** and **Location**.
⇒ Chapter 4.16, „Information on installation“ on page 73
- 2 Open drop down menu **Location** and select appropriate entry.
- 3 You may chose an image that will be displayed at the protocol as a logo. Press the button "...\" and choose the appropriate image in the directories.
- 4 Click **OK** button.
The settings are saved.

2.6 Ensuring connection

In the **Site Overview** you can view the connection status for the installed Modbus addresses. Usually the connection can be made without any problems.




Fig. 2-14: Overview installation window

For a successful connection

The connection status to the device is shown as **(A)**.



The device is operating correctly. There are no errors.



A warning exists.



An alarm is pending.



There is a discontinuity between the PC and the device.

■ Open details on connection problem

You can find more information on the problem occurring in the **Errors** window.

⇒ Chapter 4.8, „Errors“ on page 64

1 Click **Errors** button.

The **Errors** window opens. The list informs you about the actions for setting up connections.

■ Fix connection problems

- 1 Check physical connections.
- 2 Check the Modbus address settings, if necessary, recreate Modbus address.
- 3 If the connection problems still exist, contact RMG service.
⇒ „Manufacturer“ on page I

2.7 Adding further devices to the site

You can add further devices to particular installation retroactively.

■ Open the USM Settings window

- 1 Activate **Dashboard - All USMs** window.
⇒ Chapter 4.1, „Site overview“ on page 46




Fig. 2-15: Select menu entry Site Information

- 2 Click on menu **Settings** in the menu bar.
- 3 Click menu entry **USM Settings**.
The **USM Settings** window opens.

■ Setting up additional devices (USM)




Fig. 2-16: USM Settings window: Modbus

1 Click a**Add** button.

An additional device will be shown in the list.

2 Enter the device data.

⇒ „Setting up devices (Ultrasonic gas meter)“ on page 15

3 Software overview

In this chapter you will be given detailed information regarding user interface elements as well as functions and operating capabilities of the software.

Contents

3.1	Operating and display elements	26
3.2	Standard buttons	30
3.3	Status icons	31
3.4	User levels	33
3.5	Structure of the software	34
3.6	Data/readings/parameters	40
3.7	Help function	41
3.8	File types	42
3.9	Password	43
3.10	License	43

3.1 Operating and display elements

In this chapter you get an overview of the user interface for RMGView^{USM}.

You will find the description of the individual windows and functions under:

⇒ Chapter 4, „Software description“ on page 43




Fig. 3-1: Dashboard window



Fig. 3-2: Header

Header The header shows the name of the window opened. The description of the window can be found under this name in chapter "Description of the software". The content of the header for some windows changes depending on the lists, plots or parameters selected.



Fig. 3-3: Menu bar

Menu bar The menu bar contains various menus with which the functions and windows can be called up.

Using the menus you can open following windows/functions:

- **File**

Clone opened window. Close window for a device. Open and save window arrangement on the desktop. Open folder for APP data user data. Close RMGView^{USM}.

- **Reports**

Conduct device check. Output test reports as log file. Open the parameter list and the list of parameter changes. Depending on the license settings, there is the optional function of creating user-defined logs or changing existing logs.

- **Settings**

Enter user information for the device. Show or hide **Select Site** window for software start. Set communication settings for the device, change or add a new device for the selected site. Switch software to another language. Set start screen for the software to start. Show or hide tool tips display. Show or hide macro names for filtering certain data. Open the password list for the selected device, change, create and delete. Change current license settings.

- **Tools**

Open the log player. The log player plays the recorded log files in real time. Parameterize the ultrasonic gas meter with opened calibration switch. Calculate a characteristic curve correction for the values determined.

- **Help**

Open the operating instructions as a PDF file. Open the RMG website. Request information on the software.



Fig. 3-4: Multifunction bar

Multifunction bar The multifunction bar comprises single buttons.

Using these buttons you can access following data:

- **Site Overview**

List of devices that are set up for the selected site.

⇒ Chapter 4.1, „Site overview“ on page 46

- **Dashboard**

Request values and status of the selected device. The values are displayed in graphic form.

⇒ Chapter 4.2, „Dashboard“ on page 48

- **Values**

Display parameter, readings or display values.

⇒ Chapter 4.3, „Values“ on page 52

- **Lists**

Request lists for one selected ultrasonic gas meter, for all ultrasonic gas meters or for several particular ultrasonic gas meters.

⇒ Chapter 4.4, „Lists“ on page 54

- **Plots**

Request lists for one selected ultrasonic gas meter, for all ultrasonic gas meters or for several particular ultrasonic gas meters.

Open predefined or user defined plots. Create and change user defined plots.

⇒ *Chapter 4.5, „Plots“ on page 56*

- **Raw data**

Request data from selected sensors. The data is displayed with the help of a plot (graphic illustration of the values).

Create an image file of the plots.

⇒ *Chapter 4.6, „Raw data“ on page 57*

- **Logs**

Request list of actions, ParameterLog and EventLog, that are carried out via the software.

⇒ *Chapter 4.7, „Logs“ on page 59*

- **Errors**

Request list of errors and warning messages that have occurred.

⇒ *Chapter 4.8, „Errors“ on page 64*

• Password Input

Log into password-protected user level.

⇒ Chapter 4.9, „Password Input“ on page 65



A Ultrasonic gas meter preselection B Display area

C Status bar

Fig. 3-5: Dashboard window

Ultrasonic gas meter preselection (A)

The information on the selected device such as live values, functions or parameters are shown in the display area.

Display area (B)

The display area shows the contents of the windows that have been opened using the multifunction bar.

Status bar (C)


The status bar gives information on the current status of the selected device. Connection to selected device, current readings and position of the service switch and of the calibration switch. A percent display gives information on the actual utilization of the device. The status for the code word of the device is displayed.

You will find possible symbols for the actual status here:

⇒ „Status icons“ on page 29

3.2 Standard buttons

The following buttons are a feature of many windows. Their functions are the same in all windows.



Confirm the entered value. The values will be saved.



Cancel the current entry. The entered values will not be saved.



The current screen will be saved as a jpg file.



Create a new, user-defined list or plot.



Delete user-defined list or plot.



Process user-defined list or plot.



Export data.



Import data



Move an entry down a list.



Move an entry up a list.



Record values or list and stop recording.



Refresh screen.



Clone window. The selected window will be opened a second time.



Enlarge view of plot.



Display plots in original size.

3.3 Status icons

The following icons are a feature of many windows. Their functions are the same in all windows.



Calibration switch for ultrasonic electronics is closed. The parameters of the ultrasonic electronics *cannot* be programmed.



Calibration switch for ultrasonic electronics is open. The parameters of the ultrasonic electronics can be programmed.



The ultrasonic gas meter does not match the basic configuration of the CFG file. The device *cannot* be used.



The ultrasonic gas meter matches the basic configuration of the CFG file. The device can be used.



Connection between PC and the device is OK.



There is a discontinuity between PC and device.



The device is operating correctly. There is no warning.



A warning exists.



There is a defect.



The element (list or plot) is protected and cannot be changed.



The symbol is an attribute for lists or plots that are used by more than one device.



No password has been entered. Device is password-protected. Parameters that are protected by the password *cannot* be changed.



The password has been entered. Password-protected parameters can be changed.



Service switch is locked. Only for RMG service.



Service switch is open. Only for RMG service.



The user level **Monitor** is active.

⇒ „User levels“ on page 31



The user level **Operator** is active.



The user level **Configurator** is active.



The user level **Expert Mode** is active.



Performance display for correct measurements.

The performance display can be customized. You can define the thresholds in percent below which a warning message or a defect message will be displayed.

3.4 User levels

To avoid incorrect operation the RMGView^{USM} software is divided into different user levels.

These user levels are assigned to certain user groups.



Not all the contents and functions of the RMGView^{USM} are displayed for every user group.

Only after you have entered a password for the user level are the information and functions for this user group displayed and can be operated.

The description of the windows and menus indicates which user level is enabled in the respective windows or menus.

⇒ „Software description“ on page 43

The following user groups are assigned to the user level.

All user groups	Monitor No password required. This user level serves to display the contents of the windows. The data cannot be processed.
Operating personnel	Operator Password for operator required. The operating personnel can create user-defined lists, change parameters and delete user-defined lists.
Maintenance/setup personnel	Configurator Password required for Configurator. Set up all access rights and password for operating personnel.
Service personnel	Expert mode Password for Expert Mode required. All access rights for operating personnel, maintenance and setup personnel. In addition the licenses can be managed.

3.5 Structure of the software

The following chart shows the structure of the RMGView^{USM} software. Every field represents a window.




Fig. 3-6: Structure of the software



The start screen can be specified. The following windows can be selected as start screen:

- Site Overview
- Dashboard
- Lists
- Plots
- Raw data
- Logs
- Errors
- Input Password

⇒ Chapter 2.5.1, „Set up-language and start window“ on page 16




Fig. 3-7: Structure of multifunction bar




Fig. 3-8: Structure of lists




Fig. 3-9: Structure of plots




Fig. 3-10: Structure of raw data




Fig. 3-11: Structure of reports menu




Fig. 3-12: Structure of menu settings




Fig. 3-13: Structure of tools menu




Fig. 3-14: Structure of help menu

3.6 Data/readings/parameters

The data/readings/parameters are stored in a coordinate system.

Via the coordinates (letter for column and number for a row) data/readings/parameters can be addressed.

The data/readings/parameters can be opened using the ultrasonic electronics display or via the RMGView software and can be selected for tasks such as user-defined lists.

⇒ Chapter 4.13, „Site Specific, User-Defined List (plot)“ on page 69

Example Parameter structure

USM	Coordinate	Name	Value	Unit	Modbus Address
910302	H-1	to base value	122.527	m3/h	6248
					

Fig. 3-15: Structure of a parameter

As a rule, parameters are structured as follows:

- Associated USM **(A)**, e.g. 910302.
- Coordinates of the parameter **(B)**, e.g. H-1.
- Name of the parameter **(C)**, e.g. for base value.
- Value that the parameter should read out or specify **(D)**, e.g. 122.527.
- Assignment of the unit **(E)**, e.g. m3/h.
- Assignment to the Modbus address **(F)**, e.g. 6248.

3.7 Help function



Fig. 3-16: Help menu

Using the **Help** menu, you receive following information:

- details of the software version and the license number
⇒ Chapter 4.23, „License Info“ on page 93
- Software manual as a PDF file
- Website www.rmg.com

3.8 File types

The following table describes the file types (file suffixes) that are needed to work with the RMGView^{USM} software.

CSV	List with recorded values of parameters, events or plots: The list can be imported for processing in a spreadsheet program.
RPR	File contains a template for generating PDF files.
RMW	Stored screen configurations. After this file has been opened the screens will be arranged according to the settings of this file.
CFG	The file stores the configuration of an ultrasonic gas meter. Based on CFG files, differences to start configuration can be identified.
RMX	Software system files RMGView ^{USM} .
EXE	Executable files.
HTML	Output format for a RPR file, can be opened in any browser.
PDF	Output format for a RPR file, reports, graphic representation of readings (plots) or test certificate. This file can be opened by every PDF viewer.
JPG	Image file for graphics of readings (plots).
BIN	Output file for the raw data of the sensors. Recording of the signals, without any changes, from the ultrasonic electronics.
XML	File stores the RMGView settings, e.g. language settings, screen configuration.

3.9 Password

With a password you will be given access to protected user levels in the RMGView^{USM} software. On delivery of the RMGView^{USM} software, you will have received a password from RMG for every protected user level.



Should the passwords no longer be available, then request these from the RMG service.

⇒ „Manufacturer“ on page I

The user with the password to the user level **Configurator** can generate passwords with user level assignment.

⇒ Chapter 4.20, „Password List“ on page 88

3.10 License

With the help of the license you can enable the functions of the report editor, characteristic curve correction and header data for the raw data. With the report editor you can compile reports according to your requirements.

Training by RMG is required for working with the report editor.



As an alternative RMG offers the service of creating client-specific reports.



4 Software description

This chapter contains information on fields, sectors and other contents of the windows.

Operating system windows, e.g. **Save as** are not described.

You will find following information with respect to the windows:

- Name of the window.
- Details on the window path.
- Illustration of the window.
- General description of the window's functions.
- Field elements in the window.



Depending on the user level certain contents and functions of RMGView^{USM} are displayed or hidden.

⇒ Chapter 3.4, „User levels“ on page 31

Notice

The RMGView^{USM} software offers the possibility to create, organize and present data and parameters (and additionally calculated parameters) of the USM GT400 and USZ08 ultrasonic gas meters.

- **Note that certain parameter settings may change the measuring behaviour of ultrasonic gas meters.**
- **Since usually Ultrasonic gas meter and RMGViewUSM are used together it will not be distinguished between individual parameters of this units.**

Contents

4.1	Site overview	48
4.2	Dashboard	50
4.3	Values	54
4.4	Lists	56
4.5	Plots	58
4.6	Raw data	59
4.7	Logs	61
4.7.1	USM History	62
4.7.2	USM Parameter Log	63
4.7.3	USM event log	64
4.7.4	Modbus messages	65
4.8	Errors	66
4.9	Password Input	67
4.10	Record data	68
4.11	Edit list (Creating a new list)	69
4.12	New User-Defined List: Select Type	70
4.13	Site Specific, User-Defined List (plot)	71
4.14	Color, Line Thickness	73
4.15	Save Plot as jpg Image	74
4.16	Information on installation	75
4.17	USM settings	76
4.17.1	Modbus tab	77
4.17.2	Limits tab	78
4.17.3	Register Card Advanced	79
4.18	Log Player	79
4.19	Inspection Test	80
4.20	Password List	90
4.21	User Settings	91

4.22 Base line correction)	93
4.23 License Info	95
4.24 Process License	95
4.25 Report Editor	95

4.1 Site overview

RMGViewUSM > Select Site > Site Overview




Fig. 4-1: Site Overview

In the **Site Overview** window you can manage the ultrasonic gas meter.

USM Name of the ultrasonic gas meter. By clicking on an entry, you can switch to the **dashboard** of the selected ultrasonic gas meter.

⇒ „Dashboard“ on page 48

Status Connection status between ultrasonic gas meter and RMGView^{USM}.

⇒ Chapter 3.3, „Status icons“ on page 29

- Performance** Display of valid measurements in percent. Performance values <100 means invalid measurements have occurred and have been discarded.
- Flow** Volume flow rate per hour, e.g. cubic meters
- Negative value = Gas is flowing against the flow direction.
 - Positive value = Gas is flowing in the flow direction.
- Gas velocity** Velocity of the gas, e.g. meters per second.
- SoS** Speed of Sound. Speed of the ultrasonic waves that are used to measure the gas velocity.
- Switches** Configuration options for following switches:
- Calibration switch
 - Service switch
 - Password for the PC
- ⇒ Chapter 3.3, „Status icons“ on page 29

4.2 Dashboard

RMGViewUSM > Select Site> Dashboard




Fig. 4-2: Dashboard

In the window **Dashboard** you can display the current measurement values of the ultrasonic gas meter.

Status Display Symbols for the user-defined warning and alarm signals.

- SoS
- AGC
- SNR
- Profile = Profile Indication
⇒ „Profile Indication“ on page 49
- Swirl = Angle of flow of the gas in a plane.

- Configuration = Comparison of the parameters in the ultrasonic gas meter with the parameters saved in the configuration file in the RMGView^{USM}.

⇒ Chapter 3.3, „Status icons“ on page 29

USM Electronics

Display for measuring errors or hitches in the ultrasonic gas meter:

- Electronics = Status display for the ultrasonic electronics.
 - Grey = Ready for operation.
 - Yellow = Ready for operation, measurement error recognized.
 - Red = Not ready for operation.
- Paths 1-6 = Transducer's measurement paths for the gas flow. If errors occur on a path, then these are displayed as status symbols in front of the path. If an error occurs at a transducer, the transducer is highlighted in color:
 - Blue = High enough portion of valid measurements.
 - Yellow = Warning, portion of invalid measurements is too high.
 - Red = Problem, component is not ready for function.

⇒ Chapter 3.3, „Status icons“ on page 29

Profile Indication

Profile for the flow distribution in the pipe. The optimum value (reference value) for the symmetry is 1.0 and for the profile factor 1.1. and is displayed as a green dot. Deviations from the optimum value are shown in the graphics with a connecting line to a black dot. The red dashed borderline shows the limits for triggering of alarm signals. The ultrasonic gas meters are delivered with the limit values preset.

The site specific limits for warnings are set by RMG service.

Path & Transducer Statistics

Overview of the transducer's individual configurations and measurement values.

- Path = Number of the transducer path.
- Column with no name = Number of the transducers. The transducers are numbered in the ultrasonic gas meter accordingly.
- AGC dB = Automatic Gain Control (Transducer's amplifier unit) is the value of the transducer's signal amplification in decibels.
- SNR dB = Signal-to-noise ratio is the power ratio between signal and background noise in decibels.

- SoS m/s = Speed of sound for the transducer signals in meters per second.
- Perf. % = Performance of the path is the portion of valid measurements in percent. Performance values <100 means invalid measurements have occurred and have been discarded. The difference between 100 % and the percent value displayed gives the error rate.

Path Velocity	Graphic display of the gas speed measured on the transducer paths. Two matching paths, each give the gas speed for one of the three meter levels in the ultrasonic gas meter.
SoS	Graphic display of the speed of sound measured on the transducer paths.
Axial Velocity	Graphic display of the gas speed measured in the meter levels.
Tangential Velocity	Graphic display of the horizontal deviations measured to the gas's direction of flow in meters per second.
Turbulence	Graphic display of the speed and the change of direction for the gas flow. A yellow dashed line is the user-defined limit for warning signals. A red dashed line is the user-defined limit for alarm signals.
Swirl angle	Graphic display of the horizontal deviations measured in degrees of an angle in relation to the direction of gas flow. A yellow dashed line is the user-defined limit for warning signals. A red dashed line is the user-defined limit for alarm signals.

Trend overview 1




Fig. 4-3: Trend overview 1

The trend overview 1 in figure 4-3 shows the temporal behaviour of the speed of the gas along the measuring path. This can be compared with trend overview 2 in figure 4-4, that shows the SoS along the measuring paths.

Using the drop-down menu you may select predefined calculations and have these values displayed in a (new) trend overview.

Trend overview 2




Fig. 4-4: Trend overview 2

4.3 Values

RMGViewUSM > Select Site> Values




Fig. 4-5: Values

In the **Values** window you can have the actual data, measured values and parameter displayed. The data, measured values and parameter are read out via the RMGView^{USM} from the ultrasonic electronics.

Values List with predefined data, measured values or parameter lists. The parameters associated can be displayed in the right-hand window area.

Filter Filter panel for searching for data, measured values or parameters, e.g. frequency. For the search you can enter keywords or parts of keywords but not use wildcards.

USM	Name of the ultrasonic gas meter.
Coordinate	Memory cell for the parameter in the device. The parameter is stored in a coordinate system. A parameter can be addressed using the coordinates (letter for the column, number for the row). The parameter can be called up using the Lists window and selected for tasks e.g. creating user-defined lists. ⇒ „Lists“ on page 54
Name	Description of the parameter to be measured.
Value, unit	Numerical value and unit of the parameter to be measured.
Modbus address	Address of the communication protocol between PC and ultrasonic gas meter.

4.4 Lists

RMGViewUSM > Select Site > Lists




Fig. 4-6: Lists

In the **Lists** window you can, in the left-hand window sector, administer the predefined and the user-defined lists with the system parameters contained. In the right-hand window area you can view the parameter in the selected list. With lists you configure the parameter that are to be read out of the device.

Lists Universal or site specific list. A list can contain predefined or user-defined system parameter:

- Universal = Universal lists are configured with parameters for all types of ultrasonic gas meters in a site.
- Site-specific = Site-specific lists are configured with parameters for a selection of certain types of ultrasonic gas meters in a site.



- Predefined lists are marked with the symbol of a locked padlock and cannot be changed or deleted.
- User-defined lists are shown without a symbol and can be changed or deleted.



- Several meters in a list are marked with the multi-USM symbol.
 - For universal parameters the symbol contains a list with values for all ultrasonic gas meters of a site.
 - For site-specific parameters the symbol contains a list with values for all ultrasonic gas meters of a site.

Filter Filter panel for searching for data, measured values or parameters, e.g. frequency. For the search you enter keywords or parts of a keyword. You cannot use wildcards.

The columns are described in following position:

⇒ „Values“ on page 52

4.5 Plots

RMGViewUSM > Select Site > Plots




Fig. 4-7: Plots

In the **Plots** window you can show the trend as a graphic of the readings listed. Using the drop-down menu you must first select the device for the measurements.

In the left window you can select a parameter, e.g. speed of sound. In the right hand window sector the values measured for the parameter can be listed and displayed in a trend graphic.

Using the diskette symbol you can export a screenshot of the graphic displayed, as a jpg file.

⇒ „Save Plot as jpg Image“ on page 72

4.6 Raw data

RMGViewUSM > Select Site > Raw Data




Fig. 4-8: Raw data

In the **Raw Data** window you can display the readings for the individual transducers or their paths. Two connected transducers form a measurement path.

Transducer

In this window sector you can administer the parameters for the measurements.

Raw data type Filtered display type of raw data. Raw data can be displayed graphically with and without filtered values.

Only for RMG service personnel. If you have any questions or queries please contact the RMG service personnel.

⇒ „Manufacturer“ on page I

Raw data function Type of function in order to calculate raw data.

Only for RMG service personnel. If you have any questions or queries please contact the RMG service personnel.

⇒ „Manufacturer“ on page I

Path 1, 2, 3, 4, 5, 6 Measuring path for ultrasonic transducers. Two paths represent a level of the total of three levels for the measurements in the ultrasonic gas meter:

- Path 1+2 = Level 1.
- Path 3+4 = Level 2.
- Path 5+6 = Level 3.

☐ 1 Transducer for measurements in the direction of flow.
Transducer 1+2 give the flow velocity of a path.

- ☒ = Read values measured and display.
- ☐ = No measured values read.

☐ 2 Transducer for measuring against the direction of flow.
Transducer 1+2 give the flow velocity of a path.

- ☒ = Read values measured and display.
- ☐ = No measured values read.

Raw Data

In this window sector the values of the measurements and the corresponding graphic illustrations can be displayed. Using the diskette symbol you can export a screen shot of the graphic displayed, as a jpg file.

⇒ „Save Plot as jpg Image“ on page 72

4.7 Logs

RMGViewUSM > Select Site > Logs

In the **Logs** window you can manage all RMGView^{USM} reports.

In the left window sector you can select a protocol type:

- USM History = Overview of all reports created.
- USM Parameter Log = Reports of all changes to parameters.
- USM Event Log = Reports of all events that have occurred.
- Modbus Messages = Reports of the connection status.

In the right-hand window sector the reports in the report types can be displayed.

4.7.1 USM History

The **USM History** window all reports created can be displayed.





Fig. 4-9: USM History

- Time** Time stamp of the device for which a protocol entry was created.
- USM** Label of the device for which a protocol entry was created.
- Operator** Name of the user who caused an event.
- Event** Message for which a protocol entry was created.

4.7.2 USM Parameter Log

In the **USM Parameter Log** window you can display the reports for all parameters of the selected device. You select the device using the drop-down menu in the upper left hand corner.



Time	Coordinate	Name	Old Value	New Value
07.11.2013 09:23:23	AT-11	Par-Log Bischen	Auto Change	NO
07.11.2013 09:23:54	AI-17	Abschwächer Modus	AUTO_SEPARATE	OFF
20.11.2013 16:36:14	AI-5	DSP Reset	Auto Change	NO
21.11.2013 15:17:04	E-2	P1ad Freigabe	11111100	11000000
21.11.2013 15:25:05	E-2	P1ad Freigabe	11000000	11111111
21.11.2013 15:25:42	E-2	P1ad Freigabe	11111111	11000000
21.11.2013 15:36:12	AK-7	P1ad-1 c-min	300.00	360.00
21.11.2013 15:36:50	AL-7	P1ad-2 c-min	330.00	360.00
21.11.2013 15:48:54	E-2	P1ad Freigabe	11000000	11011110
21.11.2013 15:49:00	E-2	P1ad Freigabe	11011110	11111100
22.11.2013 09:05:55	AK-7	P1ad-1 c-min	360.00	300.00
22.11.2013 09:06:01	AL-7	P1ad-2 c-min	360.00	300.00
22.11.2013 12:29:26	AG-26	Testbetrieb	DEBUG	OFF
22.11.2013 12:29:37	AG-26	Testbetrieb	OFF	DEBUG
25.11.2013 13:38:15	AI-4	DSP Sendintervall	10	1
25.11.2013 13:38:48	AI-4	DSP Sendintervall	1	10
25.11.2013 13:40:35	AK-22	P1ad-1 Abklingzeit	8.00	0.00
25.11.2013 13:40:36	AL-22	P1ad-2 Abklingzeit	6.00	0.00
25.11.2013 13:40:36	AM-22	P1ad-3 Abklingzeit	6.00	0.00
25.11.2013 13:40:36	AN-22	P1ad-4 Abklingzeit	6.00	0.00
25.11.2013 13:40:36	AO-22	P1ad-5 Abklingzeit	6.00	0.00
25.11.2013 13:40:38	AP-22	P1ad-6 Abklingzeit	6.00	0.00
25.11.2013 13:41:10	AK-22	P1ad-1 Abklingzeit	0.00	8.00
25.11.2013 13:41:10	AL-22	P1ad-2 Abklingzeit	0.00	6.00
25.11.2013 13:41:11	AM-22	P1ad-3 Abklingzeit	0.00	6.00
25.11.2013 13:41:11	AN-22	P1ad-4 Abklingzeit	0.00	6.00
25.11.2013 13:41:14	AL-22	P1ad-2 Abklingzeit	8.00	6.00

Fig. 4-10: Protocols of the parameters of the selected device

Time Time stamp when a parameter change was logged.

Coordinates Memory cell for the parameters in the device. The column is described in the following position:

⇒ „Coordinate“ on page 53

Name Identifier of the parameter.

Old value Value no longer currently valid.

New value Currently valid value.

4.7.3 USM event log

In the **USM Event Log** window you can display the reports for all occurring events of the selected device. You select the device using the drop-down menu in the upper left-hand corner.




Fig. 4-11: Protocols of the parameters of the selected device

Time Time stamp when an event was logged.

Type Type of event, e.g. error.

Info Additional information on the event.

4.7.4 Modbus messages

In the **Modbus Messages** window you can display the messages of the status of the communication protocol.




Fig. 4-12: Messages to the status of the communication protocol

Time Time stamp of the device for which a protocol was created.

USM Time stamp of the ultrasonic gas meter for which a protocol was created.

Message Messages on the status of the communication protocol.

4.8 Errors

RMGViewUSM > Select Site > Errors




Fig. 4-13: Errors

In the **Errors** window you can display the warnings and error messages for the ultrasonic gas meter selected or for all ultrasonic gas meters.

USM Name of the ultrasonic gas meter.

Message Status display with messages about warnings and errors.
⇒ Chapter 3.3, „Status icons“ on page 29

4.9 Password Input

RMGViewUSM > Select Site > Multi-function Ribbon > User Symbol



Fig. 4-14: Password Input

In the **Password Input** window you can log-in for a user level. Depending on the user level you have extended access to RMGView^{USM}.



Depending on the user level certain contents and functions of RMGView^{USM} are displayed or hidden.

Radio button user groups

Radio button for selecting the user groups.

- Monitor
- Operator
- Configuration
- Expert mode

Further information on the possibilities of the user groups can be found here:

⇒ Chapter 3.4, „User levels“ on page 31

Password

Entry field for the password.

As a default setting you may use the following passwords:

- configurator: RMGUSE-P
- expert: RMGUSE-E

4.10 Record data

RMGViewUSM > Select Site > Lists > Filled Circle

RMGViewUSM > Select Site > Values > Filled Circle

In the figures, which you may see if you activate one of two links above, a small black circle on a light-grey square can be seen in the upper right corner. If you click on it with the mouse, the following window is opening.




Fig. 4-15: Record data

In the **Record Data** window you can record the trend data and save it in a file.

File Storage location and name of the file.

Time Base Recording intervals of the trend values.

As soon as the entries in this field are confirmed with "OK", the recording starts. This is indicated by changing the circle to a square. At the same time, a clock is running, which indicates the duration of the recording.

By clicking on the square the recording ends.

4.11 Edit list (Creating a new list)

RMGViewUSM > Select Site > Lists > Select List > Pencil Symbol

RMGViewUSM > Select Site > Lists > Plus Symbol > Select Type > OK Button




Fig. 4-16: Edit list

In the **Edit List** window you can process the parameter lists for the ultrasonic gas meters or create new ones. Using the parameter readings reports and maintenance reports can be created. You can reuse the parameter lists for devices of the same type.

The elements of the window are shown in the following position.

⇒ „Site Specific, User-Defined List (plot)“ on page 69

In addition following fields are displayed:

List Name Identifier for self-defined list.

Select Value Select parameters for the self-defined list.

4.12 New User-Defined List: Select Type

RMGViewUSM > Select Site > Lists > Plus Symbol




Fig. 4-17: New User-Defined List: Select Type

In the **New User-Defined List: Select Type** window you can create a new parameter list. Using parameter lists the values measured in the device can be read out.

- Display values for the selected ultrasonic gas meter.
Type is universal:
List for the selected ultrasonic gas meter. List of ultrasonic gas meters is selectable for all sites.
- Display values for all ultrasonic gas meters
Type is universal:
List of all ultrasonic gas meters in a site. List of ultrasonic gas meters is selectable for all sites.
- Display values for different, selectable ultrasonic gas meters.
Type is site-specific:
List for selected types of ultrasonic gas meters of a single site.
- Framed field:
Is only available for user level service personnel.

4.13 Site Specific, User-Defined List (plot)

*RMGViewUSM > Select Site > Lists / Plots > Plus Symbol
> Select Type > OK*




Fig. 4-18: User-defined list

In the **Edit List** window you can compile self-defined lists of parameters or measurements or self-defined lists of parameter plots Trend overviews are created using the values read out for the parameters or the values measured. You can reuse the parameter lists and parameter plots for devices of the same type.

Name of the plot	Label for plot.
Select USM	List of ultrasonic gas meters in the site.
Select value	Select parameters for the plot graphic.
Filter panel (search for values)	Text panel to filter the list of parameters.

Values in the plot

USM	Name of the ultrasonic gas meter.
Name	Parameter label for the plot.
Minimum	Minimum value for the parameter in the plot.

Maximum	Maximum value for the parameter in the plot.
Color	Name of the color for the graphic in the plot.
Line Thickness	Line thickness in pixels.

Values in the list

USM	Name of the ultrasonic gas meter.
Text	Parameter in the self-defined list.

4.14 Color, Line Thickness

RMGViewUSM > Select Site > Raw Data > Pencil Symbol

In the **Color, Line Thickness** window you can configure the graphic display of the trend curves for individual ultrasonic paths.




Fig. 4-19: Color and line size selection

Name	Name of the ultrasonic path.
Color	Specification of color.
Line Thickness	Line thickness in pixel.

4.15 Save Plot as jpg Image

RMGViewUSM > Select Site> Raw data > Diskette Symbol

RMGViewUSM > Select Site > Plots > Diskette Symbol




Fig. 4-20: Save Plot as a jpg Image

In the **Save Plot as jpg Image** window you can export the current display as a jpg image.

x Pixels Width x height of the image in pixels.

4.16 Information on installation

RMGViewUSM > Select Site > Settings > Site Information




Fig. 4-21: Site information

In the **Site Information** window you can manage the information on the client and the location of his site.

Name Station name of the site.

Customer Name of the customer.

Location Location of the site.

Always use this site, Skip Site Selection If you want to manage a single site, then you can at the start of RMGView^{USM} skip the window for Site Selection.

☒ Skip the **RMGViewUSM – Select Site** window.

☐ Open **RMGViewUSM – Select Site** window.

4.17 USM settings

RMGViewUSM > Select Site > Settings > USM Settings




Fig. 4-22: USM Settings

In the **USM Settings: Modbus** window you can conduct the configuration of the ultrasonic gas meters in the site using the tabs.

In the left window sector you can maintain the list of the ultrasonic gas meters (USM):

- Select USM
- Rename USM
- Delete USM
- Add USM

The tabs for the configuration settings for the ultrasonic gas meters and an overview of the limit values for warning and alarm signals are in the right window sector.

⇒ „Modbus tab“ on page 75

⇒ „Limits tab“ on page 76

Import This button can be used to import the configurations from a file.

Export This button can be used to export the configurations to a file.

4.17.1 Modbus tab

RMGViewUSM > Select Site > Settings > USM Settings




Fig. 4-23: USM Settings – Modbus

In this tab you configure the communications connection between RMGView^{USM} and ultrasonic gas meter.

Modbus Address Address of the ultrasonic gas meter at the bus.

- IP** Use connection via Internet protocol address of a network or a serial interface.
- ☒ Use IP address for the connection (network cable).
 - ☐ Use serial port (e.g. RS485) for the connection (serial cable).

IP Address IP address, for the connection between ultrasonic gas meter and RMGView^{USM}, e.g. 192.168.100.125.

IP Port (mostly 502) Port number of the RMGView^{USM} service for the connection via the IP Address.

Baud Rate Transfer rate for serial communication.

Bits, Parity, Stop Bits Parameter interface.

COM Port Name of the serial port for the connection between the ultrasonic gas meter and RMGView^{USM}.

Timeout Time span until a communication attempt is dropped as an error. Recommendation for connections:

- IP address = timeout of 500 ms (milliseconds).
- Serial port = timeout of 50 ms (milliseconds).

4.17.2 Limits tab

RMGViewUSM > Select Site > Settings > USM Settings > Limits




Fig. 4-24: USM Settings – Limits

Notice

Note that you have access to USE parameters here and that you can vary them. This means that the the measuring behaviour may clearly change.

4.17.3 Register Card Advanced

RMGViewUSM > Select Site > Settings > USM Settings > Register Card Advanced




Fig. 4-25: USM Settings – Register Card Advanced

With the help of the check box you may selected here to create a reference database for the selected device or not.

With “reset reference database” an existing reference database can be deleted.

The reference database is used for the function "conduct test". It stores flow rate dependent reference values.

4.18 Log Player

RMGViewUSM > Select Site > Tools > Log Player




Fig. 4-26: Log Player

Using the **Log Player** you can display a data protocol. The log-player has the standard functions e.g. play, fast-forward and pause.

4.19 Inspection Test

RMGView^{USM} > Select Site > Protocols > Inspection Test

In "**test protocol from log file**" you can create a maintenance report from a log file.



Run Inspection

90156

Log File (.log.csv)

☒ Create new

Log Duration s ☒ Cached Data ☐ Live Data

☐ use existing log file

Inspection Report (.pdf)

Reference

☐ none

☒ Reference database

☐ Existing log file

Source AGA10 SoS

☐ manual Input m/s

☒ AGA10

☐ USM calculated SoS m/s

USM measured SoS 346.098 m/s Deviation %

☒ Show AGA10 Input

Advanced Settings

Limits... Calibration...

Cancel AGA10 Input...

Fig. 4-27: Inspection Test

Here you may set parameters for an USM inspection test.

- Log file** During the test, USM data are stored in a log file. There are two possibilities:
- Create a new log file.
- RMGView^{USM} suggests a directory path as well as a file name consisting of the USM name and the current date. Also to be set is:

- Duration of the logging process in seconds
 - Whether Cache or Live data of the USM should be used
- Use an existing file
A former log file is used.
(There are not append of new data.)

Inspection report A test of an USM is documented with an inspection report. To store the inspection report name and directory path has to be defined. RMGView^{USM} suggests a filename consisting of the USM name and the current date.

Reference A USM test can be done against a reference. An internal database (flow rate dependent) or an existing log file can be used for the reference data.

Source AGA10 SoS There are the following possibilities to determine SoS, which is required for the inspection:

- Manual entry
The value of SoS is entered manually. You don't need to enter any gas data.
- AGA10
RMGView^{USM} calculates SoS based on gas data according to AGA10 rules. Gas data may be entered in the window „AGA10 measurement values“.
- Calculated by USM
The gas data are taken from the USM, which calculates SoS according to AGA10.

Extended settings Further test settings are possible clicking the following buttons:

- Limits
- Transmitter calibration
- AGA10 readings
(The start of the test is carried out in this window)

*RMGView^{USM} > Select Site > Protocols > Perform testing > **limits***

Run Inspection: Limits

90156

	Warning	Alarm	
In Plane Velocity Ratio/Ref, max	5.00	10.00	%
min Performance	85.00	33.00	%
max deviation SoS/Average	3.00	5.00	%
max Difference Dev. SoS/Ref.	5.00	10.00	%
SOS max. Devialtion to AGA10	5.00	10.00	%
AGC/Mittelwert, max 100% ±	5.00	10.00	%
AGC Average/Ref, max	5.00	10.00	%
min SNR	15.00	10.00	dB
max Swirl	10.00	15.00	°
max Turbulence	10.00	20.00	%

	Warning	Alarm	Target Value
max deviation Profile Factor	0.20	0.30	1.11
max deviation Symmetry	0.20	0.30	1.00

Cancel

OK

Fig. 4-28: Inspection test: Limits

During USM testing all characteristic parameters are monitored. In this window you can define possible deviations for each measured or calculated value, separately as warning and alarm. The percentages given are the maximum deviations from the current mean value. The turbulence is given in percent, too. The limits for warning and alarm are absolute values here.

For "max. deviation Profile Factor" and "max. deviation Symmetry" the set point has to be entered additionally.

RMGView^{USM} > Select Site > Protocols > Perform testing > **Transmitter calibration**



The dialog box titled "Run Inspection: Calibration" contains the following elements:

- A text field with the value "90156".
- A checked checkbox labeled "Show Transmitter Calibration".
- A section titled "GC Calibration" containing a table with 3 columns: "Test Run", "Found", and "Left".
- A text field labeled "Ref. Gas".
- A section titled "Pressure Tansmitter" (note the typo) containing a table with 3 columns: "Test Ref.", "Found", and "Left".
- A section titled "Temperature Transmitter" containing a table with 3 columns: "Test Ref.", "Found", and "Left".
- "Cancel" and "OK" buttons at the bottom.

Fig. 4-29: Inspection test: Calibration

In this window you may enter the calibration data of the PGC pressure and temperature transmitters. These will be displayed in the final test protocol, too.

RMGView^{USM} > Select Site > Protocols > Perform testing > **AGA10 readings**

Run Inspection: AGA10 Input

90156

Pressure
40.00
psia

Temperature
10.00
°F

Gas Components

Presets

Component	Abbr.	Mol % unnormalized	Mol % normalized
Methane	C1	0.000	0.000
Ethane	C2	0.000	0.000
Propane	C3	0.000	0.000
Iso Butane	IC4	0.000	0.000
Normal Butane	C3	0.000	0.000
Iso Pentane	IC5	0.000	0.000
Normal Pentane	NC5	0.000	0.000
Neo Pentane	nC5	0.000	0.000
Hexane+	C6+	0.000	0.000
Hexane	C6	0.000	0.000
Heptane	C7	0.000	0.000
Octane	C8	0.000	0.000
Nonane	C9	0.000	0.000
Decane	C10	0.000	0.000
Carbon Dioxide	CO2	0.038	0.038
Nitrogen	N2	78.084	78.086
Carbon Monoxide	CO	0.000	0.000
Hydr. Sulphide	H2S	0.000	0.000
Helium	He	0.000	0.000
Argon	Ar	0.934	0.934
Oxygen	O2	20.942	20.942
Hydrogen (H2)	H2	0.000	0.000
Water	H2O	0.000	0.000
Total		99.998	100.000

+

A↔B

AGA10 SoS
337.604
m/s

USM measured SoS
346.124
m/s

Deviation
-2.46
%

AGA10 Settings...

Cancel
Back
Run Inspection!

Fig. 4-30: Inspection test: AGA10 readings

This window summarizes the default values for the SoS calculation according to the AGA10. This relates to pressure, temperature and the gas components. The default values for pressure and temperature can be entered directly, too. There are also presets as defaults for the gas components.



For some known gases records already exist. These are marked with a lock symbol (see left) that means they are protected and can't be changed.

The required data can be selected from a list. New components of a gas can be entered if is chosen from empty.



Save the selected record under a new name. He is not generally protected and requires amending the only active when you create access right.



Save the selected record under its previous name.



Delete the selected record, and remove from the list of existing records.



Rename the selected record.

- With the above-mentioned default values SoS can be calculated due to AGA10. It is displayed in the window under "SOS AGA10".
- Directly under it appears the actual measured value from the USM "measurement value USM".
- Below the percental deviation of both values is displayed.

Using "AGA10-setting" you'll have access to the related parameters.

*RMGView^{USM} > Select Site > Protocols > Perform testing > AGA10 readings > **AGA settings***

Run Inspection: AGA10 Settings

90156

Source Pressure and Temperature

☐ Read from USM
☒ Input in RMGViewUSM

Pressure Unit

psia

Temperature Unit

°C

Gas Components

Normalization Method

Normalize Pro Rata

☒ Measured Components

Fixed Ratio:

	C6	C7	C8
☐	0.475	0.335	0.190
☐	0.500	0.500	0.000
☐	0.500	0.250	0.250
☐	0.500	0.250	0.250

Standard for SoS

AGA10

Cancel

OK

Fig. 4-31: Performing test: AGA10 setting

This window summarizes the settings for the SoS calculation due to AGA10.

Select the source for pressure and temperature.

- Read values from USM.
- Use the input values of RMGView^{USM}.
Check and fix the units of these values.

Use the gas components

- Select the normalization method.
A requirement for the SoS calculation due to AGA10 is that the sum of all gas components is exactly 100%. To ensure this the gas components are automatically normalized. There are two possibilities:
 - Pro-Rata method
 - Normalize On C1
- Select the gas components ratio.
The ratio between hexane C6, heptane C7 and octane C8 have to be fixed. There are 2 methods:
 - The Components be read as independent readings from USM.
 - The Components are in fixed relationship.
Three predefined combinations can be selected.
In the fourth combination of two components can be freely entered

Standard selection for SOS

There are two possibilities to calculate SoS:

- AGA10
- ISO20765

*RMGView^{USM} > Select Site > Protocols > Perform testing > AGA10 readings > **Perform Testing***

In the next figure you may see a part of a test protocol that is automatically generated after the test of the USM.

USZ08 ULTRASONIC METER INSPECTION REPORT



Location & USM Data														
USM	90166			Matrix version	134			Reference	automatic					
Site				CPU CRC	79fa									
Unit Number	90166			metrological par.	CRC32									
Log Start	23.04.2018 10:31:11			piezoelec. In. CRC	ABE1									
Log Finish	23.04.2018 10:31:20			Config. Status	Error									
Counters														
Start	23.04.2018 10:31:11			Tot. Volume d.1			Tot. Volume d.1			Tot. Volume d.2			Tot. Volume d.2	
End	23.04.2018 10:31:20			000001921.76 m³			000000642.88 m³			000000000.00 m³			000000000.00 m³	
DBL	00:00:10			0.00 m³			0.00 m³			0.00 m³			0.00 m³	
Flow Profile	Velocity(m/s)			In Plane Velocity Ratios				SWR	Profile Factor		Symmetry			
	Plane	Path		Path	Found	Ref.	Dev. (%)							
	1	1	-0.023	1/2	1.0717				0.000	0.000	0.000			
		2	-0.022											
	2	3	-0.022	3/4	-0.1963				0.000					
		4	0.010											
	3	5	0.031	6/6	3.6712			0.000						
		6	0.009											
FAIL	Marginal Limit							±10.000		1.110	±0.200	1.000	±0.200	
	Fail Limit							±15.000			±0.300		±0.300	
Performance & Speed of Sound	Performance (%)			SoS (m/s)		SoS Deviation (m/s avg. %)			Speed of Sound (m/s)					
	Plane	Path		Found	Ref.	Dev.	DBL	Water	AGA10	Dev. (%)				
	1	1	100	345.648	0.01			345.619	337.60	2.37				
		2	100	343.822	0.00									
		3	100	348.616	-0.00									
	2	4	100	348.888	-0.01									
	5	100	345.644	0.01										
	3	6	100	345.623	-0.00									
	Average		100	345.618										
PASS	Marginal Limit			95		±1.00					±0.00			
	Fail Limit			85		±1.00					±12.00			
Transducers	Transducer Gain											SNR		
	Plane	Path	Found	Ref.	Found	Ref.	Found	Ref.	Dev.	percentage correlation	1	2		
			(dB)	(dB)	(%)	(%)	(%)	(%)	(%)	(%)	(dB)	(dB)		
	1	1	16.3		99.6		16.2		100.9	4°100°ASG1(A3C1+ASG2+ASG3+ASG4)	35.30	34.69		
		2	17.3		105.8		17.0		105.7	4°100°ASG3(A3C1+ASG2+ASG3+ASG4)	36.59	36.28		
	2	3	16.9		99.6		16.8		99.4	2°100°ASG3(A3C3+ASG4)	34.42	34.67		
	4	19.0		100.4		19.0		100.6	2°100°ASG4(A3C3+ASG4)	31.45	31.89			
	5	15.6		94.6		15.4		96.1	4°ASG5(A3C1+ASG2+ASG3+ASG4)	35.99	35.96			
	3	6	16.4		100.3		16.6		97.3	4°100°ASG6(A3C1+ASG2+ASG3+ASG4)	30.69	36.92		
	Marginal Limit			100±0.0		100±0.0		100±0.0		10.0		10.0		
	Fail Limit			100±10.0		100±10.0		100±10.0		10.0		10.0		
AGA10 Input	Pressure <td colspan="2">40.0 psia</td> <td colspan="2">Constituent</td> <td colspan="2">Normalized</td> <td colspan="2">Constituent</td> <td colspan="2">Normalized</td>			40.0 psia		Constituent		Normalized		Constituent		Normalized		
	-Source			Input in RMGViewUSM				Max %				Max %		
	Temperature			10.0 °C		Methane		0.000		Hexane		0.000		
	-Source			Input in RMGViewUSM		Ethane		0.000		Heptane		0.000		
						Propane		0.000		Octane		0.000		
						Isobutane		0.000		Nonane		0.000		
					Normal Butane		0.000		Decane		0.000			
					Isopentane		0.000		Carbon Dioxide		0.038			
					Normal Pentane		0.000		Nitrogen		78.086			
					Neo Pentane		0.000		Carbon Monoxide		0.000			

Fig. 4-32: Inspection report

4.20 Password List

RMGViewUSM > Select Site > Settings > Manage Passwords




Fig. 4-33: Password List

In the **Password List** window you can manage the user and passwords.

- Name** User's name.
- Password** Password character sequence.
- Unnamed column** User level selection

4.21 User Settings

RMGView^{USM} > Select Site > Settings > User Settings




Fig. 4-34: User Settings: User Interface

In the **User Settings: User Interface** window **User Interface** you can maintain the user-defined settings in RMGView^{USM} for the graphic interface.

User data directory Source path for user interface configuration file.

**Use last folder if possible
folder as standard** Use last default setting:
☒ Use the lastly selected directory path.
☐ Do not use default setting.

CSV Delimiter	Selection of the delimiter used in CSV files. • ; = use semicolon separator. • TAB = Use tabulator separator.
..decimal point	Select the indicator for the decimal place for values. • . = Use point, e.g. 15.0 bar. • , = Use comma, e.g. 15,0 bar.
Start with..	Select the window with which RMGView^{USM} is started: • Site Overview • Dashboard • Values • Lists • Plots • Raw data • Reports • Errors
Language	Language to be used for the user interface.
Display tool tips (list)	Display information on list elements in tool tips. ☒ Display tool tips for list elements. ☐ Do not display tool tips for list elements.
Filter: Use Macro	Filter macro and display. ☒ Filter for macros and list. ☐ Do not filter for macros.

4.22 Base line correction)

RMGViewUSM > Select Site > Tools > Base line correction

The base line correction of the ultrasonic meter (USM-GT-400) can be done either with two different methods.

Base line correction of the flow rate using a polynomial fit




Fig. 4-35: Base line correction using a polynomial fit

The correction is realized using a polynomial of degree 4. This reproduces the error curve of the USM depending on the flow.

$$F = \frac{A_{-2}}{Q_m^2} + \frac{A_{-1}}{Q_m} + A_0 + A_1 \cdot Q_m + A_2 \cdot Q_m^2$$

process volume flow

Legend

F	Deviation from baseline [%]
Q_m	Process volume flow [m³/h; ..]
A_n	Constants (n = -2, -1, 0, 1, 2)

The coefficients of the polynomial are determined using the values of the deviation at the individual process flow rates.

Instead of the constant meter factor K_V the corrected factor K_{VC} will be used for further calculations.

$$K_{VC} = K_V \cdot \left(1 + \frac{F}{100}\right)$$

Legend

K_V Constant factor

The coefficients of the polynomial A_n are determined and given from the manufacturer of the USM-GT-400.

Base line correction of the flow rate using a piecewise linear interpolation




Fig. 4-36: Base line correction

This method takes into account up to 12 free choose-able set points in each direction of the flow, means in total up to 24 points. The input values from the reference are give for the x- axis. At each point of the reference the deviation of the USM has to be entered. Between the set points a linear interpolation is assumed.

Instead of the constant meter factor K_V , the corrected meter factor K_{VC} for further calculation is used:

$$K_{VC} = K_V \cdot \left(1 + \frac{F}{100}\right)$$

The set points and the deviations from the base line are given from the error curve of the USM.

The corrected process volume flow rate is then calculated using the following equation:

$$Q_{pvf} = \frac{f_v}{K_{VC}} \cdot 3600$$

Legend

Q_{pvf}	corrected process volume flow rate [m³/h, ..]
K_{VC}	corrected gas meter factor [Imp/m³]
f_v	Frequency of the meter [Hz]
K_V	uncorrected meter factor of the USM [Imp/m³]

4.23 License Info

RMGViewUSM > Select Site > Help > About RMGViewUSM

In the **License Info** window, information on the software license is displayed: If you have any questions or queries please contact the RMG service personnel.

⇒ „Manufacturer“ on page I

4.24 Process License

*RMGViewUSM > Select Site > Settings > RMGViewUSM
Process License*

4.25 Report Editor

*RMGViewUSM > Select Site > Reports > User-Defined Reports
> Report Editor*

In the **Report Editor** window you can compile protocols according to your requirements. A training by RMG is required before working with the Protocol Editor.



As an alternative RMG offers the service of creating client-specific reports.

If you have any questions or queries please contact the RMG service personnel.

⇒ „Manufacturer“ on page I

5 Operation

In this chapter you will receive information on carrying out operations with the software.

Contents

5.1	User settings	84
5.1.1	Login users	84
5.1.2	Log out users	86
5.2	Adjusting the size of graphic contents	87
5.3	Working with windows	88
5.3.1	User defined window configurations	88
5.3.2	Cloning windows	90
5.3.3	Closing RMGView ^{USM}	91
5.3.4	Close windows for a device	92
5.4	Parametrize USE	93
5.5	Open Folder User Data	97
5.6	Open Appdata Folder	98
5.7	Screen dump in jpg format	99
5.8	Reading error and warning messages	100
5.9	Creating a log of user actions	101
5.10	Creating a log on parameter changes	103

5.1 User settings

In this chapter you will receive information on logging in and out of a user level.

5.1.1 Login users

The users are assigned the access rights for the user level by logging in with their password.

■ Logging users in at a protected user level




Fig. 5-1: Opening Password Input window



The following steps are conducted from the **Dashboard - All USMs** RMGView^{USM} window.

⇒ Chapter 4.1, „Site overview“ on page 46



- 1 Click the **Password Input** button.
The **Password Input** window opens.




Fig. 5-2: Login user

- 2 Click the radio button for the user level e.g. **Configurator**.
- 3 Enter the password in the **Password** field.
- 4 Click the **OK** button.



If the password was entered correctly, the button on the **Password Input** field changes to the name of the user e.g. **Operator**.



If the password was not entered correctly the user level switches to **Monitor**.



The number of login attempts is not limited.

5.1.2 Log out users

For security reasons you must make sure that you log out of the protected user level before you leave the PC.

■ Logging out users from a protected user level

- 1 Open the **Password Input** window.

For this you carry out following steps:

⇒ Step 1, „Logging users in at a protected user level“ on page 96




Fig. 5-3: Login users


- 2 Click the **Monitor** radio button.
- 3 Click the **OK** button.

Access to the previously opened user level is disabled.

5.2 Adjusting the size of graphic contents

In order to enhance your view, you can enlarge or shrink areas of diagrams (plot).

■ Enlarging areas



A A display area of the plot. B Area marked for enlargement

Fig. 5-4:

- 1 With left mouse button pressed mark the desired area **(B)** of the plot **(A)**.
- 2 After releasing the left mouse button the view of the marked frame is enlarged.

■ Reset areas

- 1 Press the **Z** key on the keyboard.

The previously enlarged view is set back to the original size.

5.3 Working with windows

In this chapter you will receive information on organizing the windows.

5.3.1 User defined window configurations

You can arrange the windows on your desktop and save the configuration under a desired name. This configuration can be opened again any time.

■ Save Window Configuration

- 1 Open the **Dashboard - All USMs** window.
⇒ Chapter 4.1, „Site overview“ on page 46
- 2 Arrange the windows on the desktop to your requirements.




Fig. 5-5: Save window configurations

- 3 Click menu item **File** in the menu bar.
- 4 Click menu item **Workspace**.
- 5 Click menu item **Save Window Configuration**.

The arrangement of the opened windows is saved as a RMW file.



Tip!

Give the RMW file a name that you can easily recognize as being your configuration.

■ Opening window configurations

- 1 Open the **Dashboard - All USMs** window.

⇒ Chapter 4.1, „Site overview“ on page 46



Fig. 5-6: Save Window Configuration

- 2 Click menu item **File** in the menu bar.
- 3 Click menu item **Workspace**.
- 4 Click menu item **Restore Window Configuration**.

Windows are opened automatically and arranged according to the configuration on the desktop.

5.3.2 Cloning windows

■ Cloning windows




Fig. 5-7: Cloning buttons

- 
- 1

Open window that is to be opened again.
- 2

Click the **Clone window** button.
The current window is opened once again.

5.3.3 Closing RMGView^{USM}

You can close all RMGView^{USM} windows with just a few mouse clicks.

■ Exiting the software

- 1 Open the **Dashboard - All USMs** window.

⇒ Chapter 4.1, „Site overview“ on page 46




Fig. 5-8: Menu item RMGView

- 2 Click menu item **File** in the menu bar.
- 3 Click menu item **Exit RMGView USM**.

All windows of the software are closed.

5.3.4 Close windows for a device

■ Close windows




Fig. 5-9: Menu item RMGView

- 1 Click menu item **File** in the menu bar.
- 2 Click menu item **Close Window**.

The current window is closed.

5.4 Parametrize USE



To use this function you have to login as a configurator user (at minimum).

You must open the ultrasonic electronics' calibration switch so that values can be transferred to the ultrasonic electronics. Please note that for this task the lead seal must be broken. The ultrasonic gas meter may not be run with a broken seal. The device no longer has the status "calibrated".

- Only carry out these tasks if you are authorized.
⇒ *Please observe the "Operating instructions ultrasonic gas meters".*

■ Create a CSV file for parameterizing

- 1 Create a CSV file.
- 2 Remove the lead seal from the calibration switch.
- 3 Set the calibration switch to the switch position **Parameterize**, by sliding the switch upwards.

⇒ *"Operating instructions ultrasonic gas meters"*

If the calibration switch is not correctly set to the switch position **Parameterize** , then following message is displayed:




Fig. 5-10: Message

If this message is displayed, check the setting of the calibration switch.

■ Transfer CSV file to USE

- 1 Login user in at user level **Configurator**.
⇒ „Login users“ on page 96
- 2 Open the **Dashboard - All USMs** window.
⇒ Chapter 4.2, „Dashboard“ on page 48




Fig. 5-11: Menu item Parameterize USM

- 3 Click menu item **Tools** in the menu bar.
 - 4 Click menu item **Parameterize USM**.
A Windows screen for selecting a CSV file will be displayed.
 - 5 Select CSV file and confirm selection.
- The **Parameterize USE: Parameter_OB.csv** window opens.




Fig. 5-12: Select Blacklist and start process

Collect all the parameters that are not to be transferred to the ultrasonic electronics in a list. Ready-made lists (blacklists) are available.

- 6** Select blacklist.
- 7** Click the **Start** button.

The status of parameterization is illustrated by an animated time bar.

The CSV file is transferred to the ultrasonic electronics and the ultrasonic electronics are parameterized with the values from the CSV file.

Successful parameterization is displayed in the **Parameterize USE: Parameter_OB.csv** window.




Fig. 5-13: Parameterization successfully completed

- 8 Click the **Ready** button.

Parameterization is completed.

■ **Complete work on the USE**

- 9 Set the calibration switch to the switch position **Protected**, by sliding the switch downwards.

⇒ "Operating instructions ultrasonic gas meters"

- 10 Have the lead seal on the calibration switch replaced by an authorized test center.

5.5 Open Folder User Data

You can open the folder User Data using the RMGView^{USM} software.

■ Open Folder User Data

- 1 Open the **Dashboard - All USMs** window.

⇒ Chapter 4.1, „Site overview“ on page 46




Fig. 5-14: Menu item Open Folder User Data

- 2 Click menu item **File** in the menu bar.
- 3 Click menu item **Open Directory**.
- 4 Click menu item **Open Folder User Data**.

Windows Explorer opens. The filing location is displayed.

5.6 Open Appdata Folder

You can open the AppdataFolder using the RMGView^{USM} software.

■ Opening the APPDATA Folder

- 1 Open the **Dashboard - All USMs** window.

⇒ Chapter 4.1, „Site overview“ on page 46




Fig. 5-15: Menu item APPDATA Folder

- 2 Click menu item **File** in the menu bar.
- 3 Click menu item **Open Directory** .
- 4 Click menu item **Open RMGView Appdata Folder**.

The Windows explorer opens. The filing location of the APP data is displayed.

5.7 Screen dump in jpg format

You can create a jpg file of the **Plots** and **Raw Data**.

The JPG file is created in the same manner for both windows.

■ Creating the jpg file

- 1 Open the **Raw Data** window.

⇒ Chapter 4.6, „Raw data“ on page 57




Fig. 5-16: Button save as jpg image



- 2 Click the button **Save as jpg image**.

Windows Explorer opens. The jpg file is created. .

5.8 Reading error and warning messages

The RMGView^{USM} software stores error and warning messages from the ultrasonic electronics. For analysis purposes, the error and warning messages can be called up.

■ Retrieving error and warning messages




Fig. 5-17: Errors window

1 Open **Errors** window

⇒ Chapter 4.8, „Errors“ on page 64

5.9 Creating a log of user actions

Every user action executed by the user is recorded by the RMGView^{USM} software. You can open this list as a window. It is also possible to export this list as a PDF file.

■ Display log




Fig. 5-18: USM History

- 1 Click the **USM History** entry.

The **USM History** window opens. All the actions taken are listed.



The contents of the list can be filtered for a certain meter, user or for a message.

⇒ Chapter 4.7, „Logs“ on page 59

■ Creating a log file as a PDF




Fig. 5-19: Exporting a list as a PDF file

- 1 Click the **Export** button.

The **Save as...** dialog box opens. The filing location must be selected. The PDF file is created.

5.10 Creating a log on parameter changes

Every parameter change that can have an impact on the accuracy of measurement is recorded by the ultrasonic gas meter. You can open this list as a window. In addition it is possible to export this list as a PDF.

■ Display log

Time	Coordinate	Name	Old Value	New Value
07.11.2013 09:23:23	AT-11	Par-Log Bischen	Auto Change	NO
07.11.2013 09:23:54	AI-17	Abschwächer Modus	AUTO_SEPARATE	OFF
20.11.2013 16:36:14	AI-5	DSP Reset	Auto Change	NO
21.11.2013 15:17:04	E-2	Pfad Freigabe	11111100	11000000
21.11.2013 15:25:05	E-2	Pfad Freigabe	11000000	11111111
21.11.2013 15:25:42	E-2	Pfad Freigabe	11111111	11000000
21.11.2013 15:36:12	AK-7	Pfad-1 c-min	300.00	360.00
21.11.2013 15:36:50	AL-7	Pfad-2 c-min	330.00	360.00
21.11.2013 15:48:54	E-2	Pfad Freigabe	11000000	11011110
21.11.2013 15:49:00	E-2	Pfad Freigabe	11011110	11111100
22.11.2013 09:05:55	AK-7	Pfad-1 c-min	360.00	300.00
22.11.2013 09:06:01	AL-7	Pfad-2 c-min	360.00	300.00
22.11.2013 12:29:26	AG-26	Testbetrieb	DEBUG	OFF
22.11.2013 12:29:37	AG-26	Testbetrieb	OFF	DEBUG
25.11.2013 13:38:15	AI-4	DSP Sendintervall	10	1
25.11.2013 13:38:48	AI-4	DSP Sendintervall	1	10
25.11.2013 13:40:35	AK-22	Pfad-1 Abklingzeit	6.00	0.00
25.11.2013 13:40:36	AL-22	Pfad-2 Abklingzeit	6.00	0.00
25.11.2013 13:40:36	AM-22	Pfad-3 Abklingzeit	6.00	0.00
25.11.2013 13:40:36	AN-22	Pfad-4 Abklingzeit	6.00	0.00

Fig. 5-20: List of changed parameters

1 Click the **USM History** button.

The list opens. All the actions taken are listed.



The contents of the list can be filtered for a certain meter, user or for a message.

⇒ Chapter 4.7, „Logs“ on page 59



6 Troubleshooting

In this chapter you will receive information on possible problems and how you solve the problems.



If you cannot find a solution to your problem with the RMG component, then please contact the RMG service.

⇒ „Manufacturer“ on page I

Contents

6.1	Cfg file missing	118
6.1.1	Creating a cfg-file	118
6.2	Discontinuity in connection to the meter	119
6.3	Display „RMGView^{USM} is already running....“	120
6.4	Display „The file USE_112c.rmx ...“	120

6.1 Cfg file missing

The cfg file should have been filed in the specified directory during installation and should be able to be called up from there.

6.1.1 Creating a cfg-file

You can create a cfg-file in the RMGView^{USM} via the dashboard. If you move the mouse pointer over the symbol from

Status display -> Configuration

you get - in a yellow frame - the hint that you can select further features with a "right click" of the mouse.



Fig. 6-1: Features „under“ the mouse pointer

With a right-mouse-click you may now generate a new cfg-file.



Fig. 6-2: Generation of a cfg-file

The cfg-file is required to get all necessary parameters. RMGView^{USM} cyclically checks whether the parameters of the ultrasonic gas meter still match the parameters from the cfg-file.

6.2 Discontinuity in connection to the meter

The following message will be displayed: „You have just removed COM 5.“

- 1 Please check the USB cable connection from the device to the computer.

A loose USB connection could also be responsible for the timeout. The cause could also be an excessively long or poorly shielded cable.

Please only use twisted pair shielded cables up to a maximum length of 500 m. Recommended type LiYCX 2 x 2 x 0.75 mm². The green status LED at the bottom left shows if communication is operating correctly.

6.3 Display „RMGView^{USM} is already running....“

The following message will be displayed: „RMGView^{USM} is already running on COM 5.“

This means that one instance of RMGView^{USM} is already running. It cannot be started a second time at the same interface.

- Fix**
- 1 Close RMGView^{USM} or, if this doesn't work, use the Windows Task Manager, (right mouse key on the Windows task bar -> Start Task Manager) end the RMGView^{USM}.exe process in the processes tab.

If a connection from the same computer to several ultrasonic gas meters is desired, then initially, in the already opened instance of RMGView^{USM} you must switch to the second, connected COM port before RMGView^{USM} can be restarted on the standard COM port.

6.4 Display „The file USE_112c.rmx ...“

...could not be found. Get in touch with RMG in order to receive a USE_xxx.rmx file that is suitable for your USM09.

- 1 Procure an .rmx file suitable for the firmware of your ultrasonic gas meter. Disconnect your ultrasonic gas meter. Start RMGView^{USM}. Select the menu item Tools->RMGView^{USM} Open RMG APPDATA folder, copy the .rmx file into the folder displayed.
- 2 Close RMGView^{USM}.
- 3 Reconnect the ultrasonic gas meter. Start RMGView^{USM}.

7 Index

A

Abbreviations 5

C

Characteristic curve correction 80

Connection scheme 2, 9

D

Dashboard 49

Display area 29

E

Editor
Report 81

F

Files
Explanation 43
Scope of delivery 8
Types 43

I

Info
License 80

L

License 44
Info 80
process 81

List
process 67
Select Type 68
User Defined 70

Lists
Parameter 55

Logs 60
Modbus messages 62
Player 76
USM Event log 61
USM History 61
USM Parameter Log 61

M

Multifunction bar 28

O

Overview
Site 47

P

Parameter
Lists 55
Values 53

Password 29, 44

Password Input
User level 64

Password List 77

R

Report
Editor 81

Reports
see Logs 60

S

Site
Overview 47

Symbols 5

U

User group

- Configurator 34
- Expert mode 34
- Monitor 34
- Operator 34

User level

- Password Input 64

User levels 34

User Settings 78

USM

- Limits 75
- Modbus 74
- Normal conditions 75
- settings 73

V

Values

- Parameter 53

W

Window configurations. 88

8 Glossary

In this chapter you will be given information on terminology.

Ultra-sonic gas meter (USM)

The gas flows through the ultra-sonic gas meter. The flow of the gas is measured at different levels with ultra-sonic transducers.

Ultra-sonic electronics (USE)

The ultra-sonic electronics are mounted on the ultra-sonic gas meter. The ultra-sonic electronics evaluate the data recorded by the sensors. If no display is available the parameters can be displayed and evaluated on a PC with the RMGView^{USM} software.

Plot

Graphic display of one or more measured values.

Meter

In the software the ultra-sonic gas meter is sometimes called a meter.

Device

In the manual the ultra-sonic gas meter and the ultra-sonic electronics are called devices.

Transducer

The transducer or sensor is built into the device. The transducer sends the opposing transducer an ultra-sonic signal. Using the time measured for the ultra-sonic signal to travel the distance between the two transducers, the ultra-sonic electronics calculates the gas flow. 12 transducers are built into the device. They are distributed across three levels with four transducers on every level. Per level two paths measure the gas flow. A path comprises two opposing transducers.

In the manual the transducer is called a sensor.

Sensor

⇒ *Transducer*

Counter

⇒ *Ultra-sonic gas meter (USM)*

Meter

⇒ *Ultra-sonic gas meter (USM)*



Subject to technical modification.

For further information

If you would like to learn more about the products and solutions from RMG, please visit our website:

www.rmg.com

or your local support office
or contact your local sales representative.

RMG Messtechnik GmbH

Otto-Hahn-Str. 5

D-35510 Butzbach

Phone: +49 6033 897-0

Fax: +49 6033 897-0

Email: service@rmg.com

